



Overground Tank – Up to 1 Tonne

- 3m from any source of ignition (i.e. parked cars, un-protected electrical equipment)
- 1.5m from overhead cables
- Tank area to be kept clear of rubbish or combustible materials
- No Hedging/Bushes/Shrubs within 1m of the Tank
- Hedging on one side only. 1m from Tank screening

IS 3216 : 2010

calorgas.ie

